



City of Mountain View
City Hall
540 Castro Street
Post Office Box 10
Mountain View, CA 94042
(415) 967-7211

Department: Public Works
Waste Water Division
Industrial Wastes Sampling

SFUND RECORDS CTR
88172049

SFUND RECORDS CTR
2807-91878



DESIGNATED AS A
BI-CENTENNIAL CITY

November 4, 1975

Fairchild Semiconductor
464 Ellis Street
Mountain View, CA 94043

Attention: Mr. B. Yurash

RE: INDUSTRIAL WASTE VIOLATION NOTICE

Gentlemen:

Sampling of the liquid industrial waste being discharged into the City of Mountain View's sewer system by your operations has revealed the following violations:

<u>Date</u>	<u>Time</u>	<u>Violation</u>
June 18, 1975	7:20 a.m. Bldg.13	Lead 6.8 mg/l
June 18, 1975	7:40 a.m. Bldg.18	Nickel 2.9 mg/l; Zinc 15.0 mg/l; Lead 10.4 mg/l
June 23, 1975	7:35 a.m. Bldg.18	Copper 1.9 mg/l; Nickel 5.4 mg/l
October 1, 1975	8:35 a.m. Bldg. 18	Copper 7.3 mg/l; Nickel 9.1 mg/l; Chromium 1.5 mg/l; Zinc 20.8 mg/l; Lead 20+ mg/l

This violation could interfere with waste treatment processes at the Regional Water Quality Control Plant in Palo Alto and could result in your liability for the expense of re-establishing affected treatment processes.

Section 35.32.10 of the City Code has set acceptable limits for industrial waste discharges. It is requested that corrective action be taken immediately and that the Public Works office be advised of such action in writing within 15 days.

Very truly yours,

Norman H. Lougee

Norman H. Lougee
Water Division Engineer